


DOES YOUR POOL ENCLOSURE MEET THE REQUIREMENTS?

This checklist must be completed and returned with your application

GENERAL REQUIREMENTS	YES	NO
Are all sections of the fence and gate a minimum of 1.2 metres in height (4 feet)?		
Are there any projections, bracings, rails or attachments on the outside of the fence and gate that could facilitate climbing?		
Is the gap between the bottom of the gate and fence and the finished grade 5 centimeters (2 inches) or less?		

GATES	YES	NO
Are all gates constructed to be of equivalent strength as the supporting fence?		
Do all gates have an equivalent degree of safety as the supporting fence?		
Do all gates meet the height requirement of 1.2 metres (4 feet) as the fence?		
Are all gates equipped with self-closing hinges and self-latching devices on the inside of the gate at a point no less than 1.2 metres (4 feet) in height?		
Will the gate be kept locked at all times?		

CHAIN LINK FENCES	YES	NO
Is the chain link fence it constructed of at least 12-gauge wire?		
Is the size of the mesh 3.7cm or less?		



Applicant Name:

Property Address:

By signing below, I acknowledge and understand:

1. that my responses on this checklist will be verified by a City of Vaughan By-law Enforcement Officer as part of the final pool inspection process.
2. that any discrepancies between responses on this form and physical fence constructed on the subject property may result in the retention of my \$2000 pool enclosure security deposit held by the City of Vaughan and/or other penalties as per relevant bylaws

Signature:

Date:

**For any questions on fence requirements, please contact
By-Law & Compliance
905-832-2281 or bylaw.licensing@vaughan.ca**