

Yonge Street Study

Civil Infrastructure



TRUNK SANITARY SEWER
SANITARY SEWER



TRUNK STORM SEWER
STORM SEWER



TRUNK WATERMAIN
WATERMAIN

EXISTING MUNICIPAL INFRASTRUCTURE DEFICIENCIES

SANITARY SEWER
NO MAJOR CONCERNS TO REPORT

STORM SEWER
 (A) SURCHARGING 3000mm DIA TRUNK SEWER ON BROOKE STREET
 (B) CAPACITY ISSUES WITH CULVERT AND DITCH SYSTEM

WATERMAIN
NO MAJOR CONCERNS TO REPORT



SCALE: N.T.S.